




Product Service

# CERTIFICATE

No. Z2 082429 0163 Rev. 03

**Holder of Certificate:** **Risen Energy Co.,Ltd**  
Meilin, Ninghai,  
315609 Ningbo, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**



**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061900406-03

**Valid until:** 2025-09-16

**Date,** 2020-09-18

( Zhulin Zhang )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. Z2 082429 0163 Rev. 03

## Model(s):

RSM72-6-xxxM, xxx=330 to 405 in step of 5;  
RSM60-6-xxxM, xxx=275 to 340 in step of 5;  
RSM144-6-xxxM, xxx=350 to 450 in step of 5;  
RSM144-6-xxxMB, xxx=350 to 420 in step of 5  
RSM144-7-xxxM, xxx=425 to 450 in step of 5;  
RSM144-7-xxxMB, xxx=425 to 450 in step of 5  
RSM132-6-xxxM, xxx=320 to 385 in step of 5;  
RSM132-6-xxxMB, xxx=320 to 385 in step of 5  
RSM120-6-xxxM, xxx=295 to 375 in step of 5;  
RSM120-6-xxxMB, xxx=295 to 350 in step of 5  
RSM120-7-xxxM, xxx=355 to 375 in step of 5;  
RSM120-7-xxxMB, xxx=355 to 375 in step of 5  
RSM156-6-xxxM, xxx= 410 to 455 in step of 5;  
RSM156-6-xxxMB, xxx=410 to 455 in step of 5  
xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire safety Class:	Class C according to UL790
Test method of salt mist :	Test method 6

## Tested according to:

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016  
IEC 61701:2020

## Production Facility(ies):

094163, 082429, 101449, 083073, 106291